


GARDEN CITY

L.D.S. CANNERY 604 E. 46TH



QUICK ACCESS PREPLAN FORM

L 462

BUILDING ADDRESS 604 E 46
 BUILDING DESCRIPTION Block Masonry 27' tall Commercial
 Main House of Piped Roof Storage + processing
 Part Built-up Roof + new part concrete roof with skylights

C P M's Closest water Source
 Hydrant 200' towards Chardon

Needed Fire Flow -----
 1243 2481 3730 4973
 25% 50% 75% 100%

Personnel for GPM delivery including all exposures
 Personnel for all types of support
 Total personnel required

Personnel need-
 Engine Truck Chief Other

Personnel need-
 Engine Truck Chief Other

FIRE BEHAVIOR PREDICTION Involved through out structure unless at night with large doors closed could be isolated to each main area.

STRATEGY Rapid Ventilation before entering with 2-2 1/2" attack lines with 2-4 fire-compact Back-up. Possible pump Draft from Xiron for additional water or pump relay for defense mode

PROBLEMS ANTICIPATED Possible early roof collapse + access to back of building limited. Not enough water if more than 30% involved.

HAZARDS TO PERSONNEL Stopped goods on pallets falling, tossed boxes falling. Partially closed gate by burning pots

STANDPIPES ☐ yes ☒ no
 SPRINKLERS ☐ yes ☒ no